

GENERAL MEP NOTES

COORDINATION

EACH CONTRACTOR SHALL COORDINATE ITS CONSTRUCTION OPERATIONS WITH THOSE OF OTHER CONTRACTORS AND ENTITIES TO ENSURE EFFICIENT AND ORDERLY INSTALLATION OF EACH PART OF THE WORK...

- 1. SCHEDULE CONSTRUCTION OPERATIONS IN SEQUENCE REQUIRED TO OBTAIN THE BEST RESULTS WHEN INSTALLATION OF ONE PART OF THE WORK DEPENDS ON INSTALLATION OF OTHER COMPONENTS...
2. COORDINATE INSTALLATION OF DIFFERENT COMPONENTS WITH OTHER CONTRACTORS TO ENSURE MAXIMUM PERFORMANCE AND ACCESSIBILITY FOR MAINTENANCE, SERVICE, AND REPAIR.
3. MAKE ADEQUATE PROVISIONS TO ACCOMMODATE ITEMS SCHEDULED FOR LATER INSTALLATION.
4. VISIT THE SITE PRIOR TO SUBMITTING A BID TO VERIFY THE EXISTING CONDITIONS AND DESIGN CONSTRAINTS...
5. SECURE ALL PERMITS AND INSPECTIONS REQUIRED FOR WORK, AND PAY ALL FEES FOR REQUIRED WORK.
6. COMPLY WITH ALL CURRENT LAWS, BUILDING CODES AND REGULATIONS FEDERAL, STATE AND LOCAL...
7. PENETRATIONS OF WALLS AND FLOORS OF FIRE-RATED ASSEMBLIES SHALL COMPLY WITH ASTM, U.L., AND THE AUTHORITIES HAVING JURISDICTION.
8. IF THE DRAWINGS AND SPECIFICATIONS ARE IN CONFLICT THE GREATER AMOUNT OF WORK SHALL BE PRICED...
9. DRAWINGS ARE DIAGRAMMATIC AND ARE NOT INTENDED TO SHOW ALL FITTINGS, COMPONENTS AND OFFSETS...
10. CONFIRM DIMENSIONS AND LOCATIONS IN THE FIELD, DRAWINGS ARE NOT TO BE SCALED AND ARE NOT INTENDED TO SHOW EXACT LOCATIONS BASED ON SCALING DIMENSIONS.
11. GUARANTEE LABOR AND MATERIALS OF ENTIRE INSTALLATION FOR ONE YEAR...
12. ELECTRONIC COPIES OF CAD DRAWINGS OF THE CONTRACT DRAWINGS WILL NOT BE PROVIDED BY THE ENGINEER FOR CONTRACTOR'S USE IN PREPARING SUBMITTALS OR AS-BUILT DRAWINGS.

ACOUSTIC TREATMENT

- A. IT IS THE INTENT OF THESE DRAWINGS TO SPECIFY AND FOR THE CONTRACTOR TO INSTALL SYSTEMS THAT ARE QUIET AND FREE OF VIBRATION...
B. EQUIPMENT NOT MEETING THESE REQUIREMENTS SHALL BE CORRECTED BY THE CONTRACTOR TO AN ACCEPTABLE LEVEL...
C. AIR DISTRIBUTION EQUIPMENT SHALL BE SOUND TESTED AT THE DESIGN OPERATING CONDITIONS...
D. UNLESS NOTED OTHERWISE HEREIN OR ON THE DRAWINGS, THE NOISE LEVEL IN ALL OCCUPIED SPACES SHALL NOT EXCEED THE "LOWEST VALUE IN THE RANGE"...
E. SHOULD A QUESTION ARISE REGARDING THE ACCEPTABLE LEVEL OF NOISE OR VIBRATION IN A PARTICULAR SPACE OR PIECE OF EQUIPMENT, THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING THE SERVICES OF AN APPROVED ACOUSTICAL CONSULTANT...

- 1. INITIAL REVIEW: ALLOW 7 DAYS FOR INITIAL REVIEW OF EACH SUBMITTAL EXCLUSIVE OF TRAVEL TIME...
2. RESUBMITTAL REVIEW: ALLOW 7 DAYS FOR REVIEW OF EACH RESUBMITTAL EXCLUSIVE OF TRAVEL TIME.
D. PLACE A PERMANENT LABEL OR TITLE BLOCK ON EACH PAPER COPY SUBMITTAL ITEM FOR IDENTIFICATION...
E. INCLUDE THE FOLLOWING INFORMATION FOR PROCESSING AND RECORDING ACTION TAKEN:
1. PROJECT NAME.
2. DATE.
3. NAME OF ARCHITECT.
4. NAME OF ENGINEER.
5. NAME OF CONTRACTOR.
6. NAME OF SUBCONTRACTOR.
7. NAME OF SUPPLIER.
8. NAME OF MANUFACTURER.

- F. CONTRACTOR'S REVIEW: REVIEW EACH SUBMITTAL AND CHECK FOR COORDINATION WITH OTHER WORK OF THE CONTRACT AND FOR COMPLIANCE WITH THE CONTRACT DOCUMENTS...
G. ENGINEER'S ACTION: ENGINEER WILL NOT REVIEW SUBMITTALS THAT DO NOT BEAR CONTRACTOR'S APPROVAL STAMP AND WILL RETURN THEM TO THE CONTRACTOR WITH ANY BATTERY BACK-UP IS INSTALLED AND ENERGIZED...
H. ENGINEER WILL REVIEW EACH SUBMITTAL, NOTE CORRECTIONS OR MODIFICATIONS REQUIRED, AND RETURN IT. ENGINEER WILL PROVIDE SUBMITTAL WITH AN ACTION SHEET TO INDICATE ACTION.

REQUESTS FOR INFORMATION (RFI)

- 1. ENGINEER WILL RETURN RFIS SUBMITTED TO ENGINEER BY OTHER ENTITIES CONTROLLED BY CONTRACTOR WITH NO RESPONSE.
2. COORDINATE AND SUBMIT RFIS IN A PROMPT MANNER SO AS TO AVOID DELAYS IN CONTRACTOR'S WORK OR WORK OF SUBCONTRACTORS.
3. INCLUDE A PROPOSED SOLUTION AS WELL AS INCLUDING A DETAILED, LEGIBLE DESCRIPTION OF ITEM NEEDING INFORMATION OR INTERPRETATION...
4. VISIT THE SITE PRIOR TO SUBMITTING A BID TO VERIFY THE EXISTING CONDITIONS AND DESIGN CONSTRAINTS...
5. SECURE ALL PERMITS AND INSPECTIONS REQUIRED FOR WORK, AND PAY ALL FEES FOR REQUIRED WORK.
6. COMPLY WITH ALL CURRENT LAWS, BUILDING CODES AND REGULATIONS FEDERAL, STATE AND LOCAL...
7. PENETRATIONS OF WALLS AND FLOORS OF FIRE-RATED ASSEMBLIES SHALL COMPLY WITH ASTM, U.L., AND THE AUTHORITIES HAVING JURISDICTION.
8. IF THE DRAWINGS AND SPECIFICATIONS ARE IN CONFLICT THE GREATER AMOUNT OF WORK SHALL BE PRICED...
9. DRAWINGS ARE DIAGRAMMATIC AND ARE NOT INTENDED TO SHOW ALL FITTINGS, COMPONENTS AND OFFSETS...
10. CONFIRM DIMENSIONS AND LOCATIONS IN THE FIELD, DRAWINGS ARE NOT TO BE SCALED AND ARE NOT INTENDED TO SHOW EXACT LOCATIONS BASED ON SCALING DIMENSIONS.
11. GUARANTEE LABOR AND MATERIALS OF ENTIRE INSTALLATION FOR ONE YEAR...
12. ELECTRONIC COPIES OF CAD DRAWINGS OF THE CONTRACT DRAWINGS WILL NOT BE PROVIDED BY THE ENGINEER FOR CONTRACTOR'S USE IN PREPARING SUBMITTALS OR AS-BUILT DRAWINGS.

RECORD DRAWINGS

- A. WITHIN 90 DAYS OF COMPLETION OF THE PROJECT, THE CONTRACTOR SHALL SUBMIT TO THE ENGINEER A COMPLETE SET OF "AS BUILT" DRAWINGS PORTRAYING ACTUAL SITE CONDITIONS...
B. WITHIN 90 DAYS OF COMPLETION OF THE PROJECT, THE CONTRACTOR SHALL SUBMIT TO THE ENGINEER A COMPLETE SET OF "OAM MANUALS", EQUIPMENT DATA, HVAC AIR AND WATER BALANCING REPORT, AND LIGHTING CONTROL TESTING REPORT...
C. TRANSVERSE JOINTS: SELECT JOINT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
D. LONGITUDINAL SEAMS: SELECT SEAM TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
E. ELBOWS, TRANSITIONS, OFFSETS, BRANCH CONNECTIONS, AND OTHER DUCT CONSTRUCTION: SELECT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
F. ALL JOINTS AND CONNECTIONS SHALL BE MADE WITH 1/2" WIDE STAINLESS STEEL DUCT CLAMPS OR 100% NYLON SELF-LOCKING CLAMPS...
G. CHILLED WATER PIPING, ABOVEGROUND, NPS 2 (DN 50) AND SMALLER, SHALL BE THE FOLLOWING:
1. SCHEDULE 40 STEEL PIPE, CLASS 150, MALLEABLE-IRON, 250, CAST-IRON AND 300, MALLEABLE-IRON FITTINGS, CAST-IRON FLANGES AND FLANGE FITTINGS, AND THREADED JOINTS.
2. RRR PRODUCTS, INC.; INSUL-MATE STRAPPING, SEALS, AND SPRINGS.
3. ALUMINUM FASTENERS: 202 (ASTM B 209), 3003, 5052, OR 5056; TEMPER H-14, 0.020 INCH (0.51 MM) THICK, 1/2 INCH (12.7 MM) WIDE WITH WING SEAL OR CLOSED SEAL.
4. INSULATION PINS AND HANGERS: CAPACITOR-DISCHARGE WELD PINS, FULLY ANNEALED FOR CAPACITOR-DISCHARGE WELDING, 0.106-INCH-(2.68-MM) DIAMETER SHANK, LENGTH TO SUIT; DEPTH OF INSULATION INDICATED; PRODUCTS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE ONE OF THE FOLLOWING:
1. AGM INDUSTRIES, INC.; CWP-1.
2. GOMEX, CO.
3. MOWEST FASTENERS, INC.; CD.
4. NELSON STUD WELDING, TPA, TPC, AND TPS.
5. INSTALLATION OF MINERAL-FIBER INSULATION: BLANKET INSULATION INSTALLATION ON DUCTS AND PLENUMS; SECURE WITH ADHESIVE AND INSULATION PINS. APPLY VAPOR-BARRIER MANUFACTURER'S RECOMMENDED COVERAGE RATES PER UNIT AREA, FOR 100 PERCENT COVERAGE OF DUCT AND PLENUM SURFACES. APPLY ADHESIVE TO ENTIRE CIRCUMFERENCE OF DUCTS AND TO ALL SURFACES OF FITTINGS AND TRANSITIONS. INSTALL INSULATION OVER VAPOR-BARRIER. WELD PINS AND SPEED WASHERS OR CLIPPED-HEAD, CAPACITOR-DISCHARGE-WELD PINS ON SIDES AND BOTTOM OF HORIZONTAL DUCTS AND SIDES OF VERTICAL DUCTS AS FOLLOWS:
1. ON DUCT SIDES WITH DIMENSIONS 18 INCHES (450 MM) AND SMALLER, PLACE PINS ALONG LONGITUDINAL CENTERLINE OF DUCT. SPACE 3 INCHES (75 MM) MAXIMUM FROM INSULATION END JOINTS, AND 16 INCHES (400 MM) O.C.
2. ON DUCT SIDES WITH DIMENSIONS LARGER THAN 18 INCHES (450 MM), PLACE PINS WITH 3 INCHES (400 MM) O.C. EACH WAY, AND 3 INCHES (75 MM) MAXIMUM FROM INSULATION JOINTS. INSTALL ADDITIONAL PINS TO HOLD INSULATION TIGHTLY AGAINST SURFACE AT CROSS BRANCH.
3. PINS MAY BE OMITTED FROM TOP SURFACE OF HORIZONTAL, RECTANGULAR DUCTS AND PLENUMS.
4. DO NOT OVERCOMPRESS INSULATION DURING INSTALLATION.
5. IMPALE INSULATION OVER PINS AND ATTACH SPEED WASHERS.
6. CUT EXCESS PORTION OF PINS EXTENDING BEYOND SPEED WASHERS OR BEND PARALLEL WITH INSULATION SURFACE. COVER EXPOSED PINS AND WASHERS WITH MATCHING INSULATION FACING.
FOR DUCTS AND PLENUMS WITH SURFACE TEMPERATURES BELOW AMBIENT, INSTALL A CONTINUOUS UNBROKEN VAPOR BARRIER. CREATE A FACING LAP FOR LONGITUDINAL SEAMS AND END JOINTS WITH INSULATION BY REMOVING 2 INCHES (50 MM) FROM ONE EDGE AND ONE END OF INSULATION SEGMENT. SECURE LAPS TO ADJACENT INSULATION SECTION WITH 1/2-INCH (12.7-MM) OUTWARD-CLIPPING STAPLES, 1 INCH (25 MM) O.C. INSTALL VAPOR BARRIER CONSISTING OF FACTORY- OR FIELD-APPLIED JACKET, ADHESIVE, VAPOR-BARRIER MASTIC, AND SEALANT AT JOINTS, SEAMS, AND PROTRUSIONS.
1. REPAIR PUNCTURES, TEARS, AND PENETRATIONS WITH TAPE OR MASTIC TO MAINTAIN VAPOR-BARRIER SEAL.
2. INSTALL VAPOR STOPS FOR DUCTWORK AND PLENUMS OPERATING BELOW 50 DEG F (10 DEG C) AT 18-FOOT (5.5-M) INTERVALS. VAPOR STOPS SHALL CONSIST OF VAPOR-BARRIER MASTIC APPLIED IN A Z-SHAPED PATTERN OVER INSULATION FACE, ALONG BUTT END OF INSULATION, AND OVER THE SURFACE. COVER INSULATION FACE AND SURFACE TO BE INSULATED A MINIMUM OF TWO TIMES THE INSULATION THICKNESS, BUT NOT LESS THAN 3 INCHES (75 MM).
OVERLAP UNFACED BLANKETS A MINIMUM OF 2 INCHES (50 MM) ON LONGITUDINAL SEAMS AND END JOINTS. AT END JOINTS, SEAMS, AND TRANSITIONS, APPLY A MAXIMUM OF 18 INCHES (450 MM) O.C. INSTALL INSULATION ON RECTANGULAR DUCT ELBOWS AND TRANSITIONS WITH A FULL INSULATION SECTION FOR EACH SURFACE. INSTALL INSULATION ON ROUND AND FLAT-OVAL DUCT ELBOWS WITH INDIVIDUAL FITTINGS AND TRANSITIONS WITH INSULATION. INSULATE DUCT STIFFENERS, HANGERS, AND FLANGES THAT PROTRUDE BEYOND INSULATION SURFACE WITH 6-INCH-(150-MM) WIDE STRIPS OF SAME MATERIAL USED TO INSULATE DUCT. SECURE ON ALTERNATING SIDES OF STIFFENER, HANGER, AND FLANGE WITH PINS SPACED 6 INCHES (150 MM) O.C.

REQUIRED SUBMITTALS

- A. PROVIDE FOUR BOUND PRODUCT DATA SUBMITTALS FOR THE NEW EQUIPMENT LISTED BELOW TO THE ARCHITECT/ENGINEER...
B. SYSTEMS ADJUSTING AND BALANCING: HVAC SYSTEMS SHALL BE BALANCED IN ACCORDANCE WITH GENERALLY ACCEPTED ENGINEERING STANDARDS...
C. AIR SYSTEMS BALANCING: EACH SUPPLY AIR OUTLET AND ZONE TERMINAL DEVICE SHALL BE EQUIPPED WITH MEANS FOR AIR BALANCING...
D. HYDRONIC SYSTEM BALANCING: INDIVIDUAL HYDRONIC HEATING AND COOLING COILS SHALL BE EQUIPPED WITH MEANS FOR BALANCING AND MEASURING FLOW...
E. FUNCTIONAL PERFORMANCE TESTING: FUNCTIONAL PERFORMANCE TESTING SHALL BE CONDUCTED...
F. CONTROLS: HVAC AND SERVICE WATER HEATING CONTROL SYSTEMS SHALL BE TESTED TO DOCUMENT THAT CONTROL DEVICES, COMPONENTS, EQUIPMENT AND SYSTEMS ARE CALIBRATED AND ADJUSTED AND OPERATE IN ACCORDANCE WITH APPROVED PLANS AND SPECIFICATIONS...
G. ECONOMIZERS: AIR ECONOMIZERS SHALL UNDERGO A FUNCTIONAL TEST TO DETERMINE THAT THEY OPERATE IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.

MECHANICAL AND SERVICE WATER HEATING COMMISSIONING

- A. ALL REQUIREMENTS SHALL BE PERFORMED PER THE CURRENTLY ADOPTED ENERGY CONSERVATION CODE IN THE AUTHORITY HAVING JURISDICTION...
B. SYSTEMS ADJUSTING AND BALANCING: HVAC SYSTEMS SHALL BE BALANCED IN ACCORDANCE WITH GENERALLY ACCEPTED ENGINEERING STANDARDS...
C. AIR SYSTEMS BALANCING: EACH SUPPLY AIR OUTLET AND ZONE TERMINAL DEVICE SHALL BE EQUIPPED WITH MEANS FOR AIR BALANCING...
D. HYDRONIC SYSTEM BALANCING: INDIVIDUAL HYDRONIC HEATING AND COOLING COILS SHALL BE EQUIPPED WITH MEANS FOR BALANCING AND MEASURING FLOW...
E. FUNCTIONAL PERFORMANCE TESTING: FUNCTIONAL PERFORMANCE TESTING SHALL BE CONDUCTED...
F. CONTROLS: HVAC AND SERVICE WATER HEATING CONTROL SYSTEMS SHALL BE TESTED TO DOCUMENT THAT CONTROL DEVICES, COMPONENTS, EQUIPMENT AND SYSTEMS ARE CALIBRATED AND ADJUSTED AND OPERATE IN ACCORDANCE WITH APPROVED PLANS AND SPECIFICATIONS...
G. ECONOMIZERS: AIR ECONOMIZERS SHALL UNDERGO A FUNCTIONAL TEST TO DETERMINE THAT THEY OPERATE IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.

LIGHTING SYSTEM FUNCTIONAL TESTING

- A. ALL REQUIREMENTS SHALL BE PERFORMED PER THE CURRENTLY ADOPTED ENERGY CONSERVATION CODE IN THE AUTHORITY HAVING JURISDICTION...
B. OCCUPANT SENSOR CONTROLS: WHERE OCCUPANT SENSOR CONTROLS ARE PROVIDED, THE FOLLOWING PROCEDURES SHALL BE PERFORMED:
1. CERTIFY THAT THE OCCUPANT SENSOR HAS BEEN LOCATED AND AIMED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS...
2. VERIFY CORRECT OPERATION.
3.4. FOR AUTO-ON OCCUPANT SENSOR CONTROLS, THE LIGHTS TURN ON TO THE PERMITTED LEVEL WHEN AN OCCUPANT ENTERS THE SPACE.
3.5. FOR MANUAL-ON OCCUPANT SENSOR CONTROLS, THE LIGHTS TURN ON ONLY WHEN MANUALLY ACTIVATED.
3.6. THE LIGHTS ARE NOT INCORRECTLY TURNED ON BY MOVEMENT IN ADJACENT AREAS OR BY HVAC OPERATION.
C. TIME-SWITCH CONTROLS: WHERE TIME-SWITCH CONTROLS ARE PROVIDED, THE FOLLOWING PROCEDURES SHALL BE PERFORMED:
1. CONFIRM THAT THE TIME-SWITCH CONTROL IS PROGRAMMED WITH ACCURATE WEEKDAY, WEEKEND AND HOLIDAY SCHEDULES...
2. VERIFY THE CORRECT TIME AND DATE IN THE TIME SWITCH.
3. VERIFY THAT ANY BATTERY BACK-UP IS INSTALLED AND ENERGIZED.
4. VERIFY THAT THE OVERRIDE TIME LIMIT IS SET TO NOT MORE THAN 2 HOURS.
5. SIMULATE OCCUPIED CONDITION.
6.1. ALL OCCUPIED CONDITIONS SHALL BE TURNED ON AND OFF BY THEIR RESPECTIVE AREA CONTROL SWITCH.
6.2. THE SWITCH ONLY OPERATES LIGHTING IN THE ENCLOSED SPACE IN WHICH THE SWITCH IS LOCATED.
7. SIMULATE UNOCCUPIED CONDITION. VERIFY AND DOCUMENT THE FOLLOWING:
7.1. NONEMERGENCY LIGHTING TURNS OFF.
7.2. MANUAL OVERRIDE SWITCH ALLOWS ONLY THE LIGHTS IN THE ENCLOSED SPACE WHERE THE OVERRIDE SWITCH IS LOCATED TO TURN ON OR REMAIN ON UNTIL THE NEXT SCHEDULED SHUTOFF OCCURS.
8. ADDITIONAL TESTING AS SPECIFIED BY THE REGISTERED DESIGN PROFESSIONAL.
D. DAYLIGHT RESPONSIVE CONTROLS: WHERE DAYLIGHT RESPONSIVE CONTROLS ARE PROVIDED, THE FOLLOWING SHALL BE VERIFIED:
1. CONTROL DEVICES HAVE BEEN PROPERLY LOCATED, FIELD CALIBRATED AND SET FOR ACCURATE SETPOINTS AND THRESHOLD LIGHT LEVELS.
2. DAYLIGHT CONTROLLED LIGHTING LOADS ADJUST TO LIGHT LEVEL SET POINTS IN RESPONSE TO AVAILABLE DAYLIGHT.
3. THE LOCATIONS OF CALIBRATION ADJUSTMENT EQUIPMENT ARE READILY ACCESSIBLE ONLY TO AUTHORIZED PERSONNEL.

MECHANICAL SPECIFICATIONS

SINGLE-WALL RECTANGULAR DUCTS AND FITTINGS

- A. GENERAL FABRICATION REQUIREMENTS: COMPLY WITH SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE" BASED ON REQUIRED STATIC-PRESSURE CLASS UNLESS OTHERWISE INDICATED.
B. TRANSVERSE JOINTS: SELECT JOINT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
C. LONGITUDINAL SEAMS: SELECT SEAM TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
D. ELBOWS, TRANSITIONS, OFFSETS, BRANCH CONNECTIONS, AND OTHER DUCT CONSTRUCTION: SELECT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
E. ALL JOINTS AND CONNECTIONS SHALL BE MADE WITH 1/2" WIDE STAINLESS STEEL DUCT CLAMPS OR 100% NYLON SELF-LOCKING CLAMPS...
F. IF IT COMPLIES WITH THESE SPECIFICATIONS, FLEXIBLE DUCTWORK OF THE FOLLOWING TYPES WILL BE ACCEPTABLE:
FLEXMASTER TYPE 2M OR APPROVED EQUAL (EQUIVALENT TO RS).

SINGLE-WALL ROUND AND FLAT-OVAL DUCTS AND FITTINGS

- A. GENERAL FABRICATION REQUIREMENTS: COMPLY WITH SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE" CHAPTER 3, "ROUND, OVAL AND FLEXIBLE DUCT"...
B. TRANSVERSE JOINTS: SELECT JOINT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
C. LONGITUDINAL SEAMS: SELECT SEAM TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
D. ELBOWS, TRANSITIONS, OFFSETS, BRANCH CONNECTIONS, AND OTHER DUCT CONSTRUCTION: SELECT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
E. TEES AND LATERALS: SELECT TYPES AND FABRICATE ACCORDING TO SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE"...
F. WROUGHT-STEEL FITTINGS: ASTM A 234/A 234M, WALL THICKNESS TO MATCH ADJOINING PIPE.
G. WROUGHT CAST- AND FORGED-STEEL FLANGES AND FLANGED FITTINGS: ASTM B16.5, INCLUDING BOLTS, NUTS, AND GASKETS OF THE FOLLOWING MATERIAL GROUP, END CONNECTIONS, AND FACINGS.
1. MATERIAL GROUP: 1.1. END CONNECTIONS: 40100.
2. FACINGS: RAISED FACE.
H. GROOVED MECHANICAL-JOINT FITTINGS AND COUPLINGS: MANUFACTURERS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCTS BY ONE OF THE FOLLOWING:
1. ANVI INTERNATIONAL, INC.
2. CENTRAL SPRINKLER COMPANY; A DIVISION OF TYCO FIRE & BUILDING PRODUCTS.
3. NATIONAL FITTINGS, INC.
4. S.P. FITTINGS; A DIVISION OF STAR PIPE PRODUCTS.
5. VICTAULIC COMPANY.
I. JOINT FITTINGS: ASTM A 536, GRADE 65-45-12 DUCTILE IRON; ASTM A 47/A 47M, GRADE 32510 MALLEABLE IRON; ASTM A 53/A 53M, TYPE F, OR S, GRADE B FABRICATED STEEL; OR ASTM A 106, GRADE B STEEL FITTINGS WITH GROOVES OR SHOULDERS.
J. CHILLED-WATER PIPING, ABOVEGROUND, NPS 2 (DN 50) AND LARGER, SHALL BE ANY OF THE FOLLOWING:
1. SCHEDULE 40 STEEL PIPE, WROUGHT-STEEL FITTINGS AND WROUGHT-CAST OR FORGED-STEEL FLANGES AND FLANGE FITTINGS, AND WELDED AND FLANGED JOINTS.
2. SCHEDULE 40 STEEL PIPE, GROOVED, MECHANICAL JOINT COUPLING AND FITTINGS; AND GROOVED, MECHANICAL JOINTS.
K. CONDENSATE-DRAIN PIPING: TYPE M (C) DRAWN-TEMPER COPPER TUBING, WROUGHT-COPPER FITTINGS, AND SOLDERED JOINTS.
L. HANGERS AND SUPPORTS: INSTALL THE FOLLOWING PIPE ATTACHMENTS:
1. ADJUSTABLE STEEL CLEVIS HANGERS FOR INDIVIDUAL HORIZONTAL PIPING LESS THAN 20 FEET (6 M) LONG.
2. ADJUSTABLE ROLLER HANGERS AND SPRING HANGERS FOR INDIVIDUAL HORIZONTAL PIPING 20 FEET (6 M) OR LONGER.
3. PIPE ROLLER: MSS SP-58, TYPE 44 FOR MULTIPLE HORIZONTAL PIPING 20 FEET (6 M) OR LONGER, SUPPORTED ON A TRAPEZE.
4. SPRING HANGERS TO SUPPORT VERTICAL RISERS.
5. PROVIDE COPPER-CLAD HANGERS AND SUPPORTS FOR HANGERS AND SUPPORTS IN DIRECT CONTACT WITH COPPER PIPE.
M. INSTALL HANGERS FOR STEEL PIPING WITH THE FOLLOWING MAXIMUM SPACING AND MINIMUM ROD SIZES:
1. NPS 3/4 (DN 20): MAXIMUM SPAN, 7 FEET (2.1 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
2. NPS 1 (DN 25): MAXIMUM SPAN, 7 FEET (2.1 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
3. NPS 1-1/2 (DN 40): MAXIMUM SPAN, 9 FEET (2.7 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
4. NPS 2 (DN 50): MAXIMUM SPAN, 10 FEET (3 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
5. NPS 2-1/2 (DN 65): MAXIMUM SPAN, 11 FEET (3.4 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
6. NPS 3 (DN 80): MAXIMUM SPAN, 12 FEET (3.7 M); MINIMUM ROD SIZE, 1/2 INCH (12.7 MM).
7. NPS 4 (DN 100): MAXIMUM SPAN, 14 FEET (4.3 M); MINIMUM ROD SIZE, 1/2 INCH (12.7 MM).
8. NPS 4 (DN 150): MAXIMUM SPAN, 15 FEET (4.6 M); MINIMUM ROD SIZE, 1/2 INCH (12.7 MM).
9. NPS 6 (DN 200): MAXIMUM SPAN, 19 FEET (5.8 M); MINIMUM ROD SIZE, 5/8 INCH (16 MM).
10. NPS 8 (DN 250): MAXIMUM SPAN, 20 FEET (6.1 M); MINIMUM ROD SIZE, 3/4 INCH (19 MM).
11. NPS 12 (DN 300): MAXIMUM SPAN, 23 FEET (7 M); MINIMUM ROD SIZE, 7/8 INCH (22 MM).
12. NPS 14 (DN 350): MAXIMUM SPAN, 25 FEET (7.6 M); MINIMUM ROD SIZE, 1 INCH (25 MM).
N. INSTALL HANGERS FOR DRAWN-TEMPER COPPER PIPING WITH THE FOLLOWING MAXIMUM SPACING AND MINIMUM ROD SIZES:
1. NPS 3/4 (DN 20): MAXIMUM SPAN, 5 FEET (1.5 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
2. NPS 1 (DN 25): MAXIMUM SPAN, 5 FEET (1.5 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
3. NPS 1-1/2 (DN 40): MAXIMUM SPAN, 6 FEET (1.8 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
4. NPS 2 (DN 50): MAXIMUM SPAN, 8 FEET (2.4 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
5. NPS 2-1/2 (DN 65): MAXIMUM SPAN, 9 FEET (2.7 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
6. NPS 3 (DN 80): MAXIMUM SPAN, 10 FEET (3 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
O. CHILLED WATER AND BRINE, ABOVE 40 DEG F (5 DEG C):
1. NPS 12 (DN 300) AND SMALLER: INSULATION SHALL BE THE FOLLOWING: MINERAL-FIBER, PREFORMED PIPE, TYPE L, 1-1/2 INCHES (38 MM) THICK.
2. NPS 14 (DN 350) AND LARGER: INSULATION SHALL BE ONE OF THE FOLLOWING: MINERAL-FIBER PREFORMED PIPE, TYPE L, 1-1/2 INCHES (38 MM) THICK.
P. CONDENSATE AND EQUIPMENT DRAIN WATER BELOW 60 DEG F (16 DEG C):
1. ALL PIPE SIZES: INSULATION SHALL BE ONE OF THE FOLLOWING: MINERAL-FIBER, PREFORMED PIPE INSULATION, TYPE L: 1 INCH (25 MM) THICK.

SHEET METAL DUCTWORK

- A. GENERAL MATERIAL REQUIREMENTS: COMPLY WITH SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE" CHAPTER 3, "ROUND, OVAL AND FLEXIBLE DUCT"...
B. GALVANIZED STEEL SHEET: COMPLY WITH ASTM A 653/A 653M.
C. SUPPLY AND RETURN DUCTWORK SHALL BE EXTERNALLY INSULATED WITH EXTERNAL BLANKET INSULATION...
D. DUCT DIMENSIONS ARE INSIDE CLEAR DIMENSIONS.
E. THE INTERIOR SURFACE OF ALL DUCTWORK SHALL BE SMOOTH WITH NO SHEETMETAL OR OTHER PARTS PROJECTING INTO THE AIR STREAM...
F. INSULATION SHALL BE TESTED TO DOCUMENT THAT CONTROL DEVICES, COMPONENTS, EQUIPMENT AND SYSTEMS ARE CALIBRATED AND ADJUSTED AND OPERATE IN ACCORDANCE WITH APPROVED PLANS AND SPECIFICATIONS...
G. ECONOMIZERS: AIR ECONOMIZERS SHALL UNDERGO A FUNCTIONAL TEST TO DETERMINE THAT THEY OPERATE IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.

HVAC FILTRATION AND AIR QUALITY

- A. UNO, EACH NEW EQUIPMENT SHALL BE PROVIDED WITH A PRE-FILTER WITH A MINIMUM EFFICIENCY OF MERV-11...
B. UNO, EACH NEW EQUIPMENT SHALL BE PROVIDED WITH A BI-POLAR IONIZATION DEVICE(S) THAT MUST MEET UL-2998 STANDARD CERTIFICATION...
C. TIME-SWITCH CONTROLS: WHERE TIME-SWITCH CONTROLS ARE PROVIDED, THE FOLLOWING PROCEDURES SHALL BE PERFORMED:
1. CONFIRM THAT THE TIME-SWITCH CONTROL IS PROGRAMMED WITH ACCURATE WEEKDAY, WEEKEND AND HOLIDAY SCHEDULES...
2. VERIFY THE CORRECT TIME AND DATE IN THE TIME SWITCH.
3. VERIFY THAT ANY BATTERY BACK-UP IS INSTALLED AND ENERGIZED.
4. VERIFY THAT THE OVERRIDE TIME LIMIT IS SET TO NOT MORE THAN 2 HOURS.
5. SIMULATE OCCUPIED CONDITION.
6.1. ALL OCCUPIED CONDITIONS SHALL BE TURNED ON AND OFF BY THEIR RESPECTIVE AREA CONTROL SWITCH.
6.2. THE SWITCH ONLY OPERATES LIGHTING IN THE ENCLOSED SPACE IN WHICH THE SWITCH IS LOCATED.
7. SIMULATE UNOCCUPIED CONDITION. VERIFY AND DOCUMENT THE FOLLOWING:
7.1. NONEMERGENCY LIGHTING TURNS OFF.
7.2. MANUAL OVERRIDE SWITCH ALLOWS ONLY THE LIGHTS IN THE ENCLOSED SPACE WHERE THE OVERRIDE SWITCH IS LOCATED TO TURN ON OR REMAIN ON UNTIL THE NEXT SCHEDULED SHUTOFF OCCURS.
8. ADDITIONAL TESTING AS SPECIFIED BY THE REGISTERED DESIGN PROFESSIONAL.
D. DAYLIGHT RESPONSIVE CONTROLS: WHERE DAYLIGHT RESPONSIVE CONTROLS ARE PROVIDED, THE FOLLOWING SHALL BE VERIFIED:
1. CONTROL DEVICES HAVE BEEN PROPERLY LOCATED, FIELD CALIBRATED AND SET FOR ACCURATE SETPOINTS AND THRESHOLD LIGHT LEVELS.
2. DAYLIGHT CONTROLLED LIGHTING LOADS ADJUST TO LIGHT LEVEL SET POINTS IN RESPONSE TO AVAILABLE DAYLIGHT.
3. THE LOCATIONS OF CALIBRATION ADJUSTMENT EQUIPMENT ARE READILY ACCESSIBLE ONLY TO AUTHORIZED PERSONNEL.

FLEXIBLE DUCTWORK

- A. FLEXIBLE DUCT SHALL BE USED FOR CONNECTIONS TO AIR DISTRIBUTION DEVICES WHERE SHOWN ON THE DRAWINGS OR SPECIFIED HEREIN...
B. INSULATED FLEXIBLE DUCT SHALL BE A FACTORY FABRICATED ASSEMBLY CONSISTING OF A GALVANIZED STEEL OR SPIRAL ALUMINUM HELIX...
C. THE FLEXIBLE DUCT ASSEMBLY SHALL BE SUITABLE FOR A MINIMUM OF 4" WC WORKING PRESSURE...
D. FLEXIBLE DUCTS SHALL BE STANDARD IN SUCH A MANNER TO PREVENT SAGS AND KINKS...
E. ALL JOINTS AND CONNECTIONS SHALL BE MADE WITH 1/2" WIDE STAINLESS STEEL DUCT CLAMPS OR 100% NYLON SELF-LOCKING CLAMPS...
F. IF IT COMPLIES WITH THESE SPECIFICATIONS, FLEXIBLE DUCTWORK OF THE FOLLOWING TYPES WILL BE ACCEPTABLE:
FLEXMASTER TYPE 2M OR APPROVED EQUAL (EQUIVALENT TO RS).

CONTROLS

PROVIDE ALL TEMPERATURE CONTROLS MODIFICATIONS REQUIRED FOR A COMPLETE AND FUNCTIONING CONTROLS SYSTEM. ALL CONTROLS SHALL MATCH BUILDING STANDARD.

CHILLED WATER / CONDENSATE PIPING

- A. STEEL PIPE: ASTM A 53/A 53M, BLACK STEEL WITH PLAIN ENDS.
B. CAST-IRON THREADED FITTINGS: ASME B16.4, CLASSES 125 AND 250.
C. MALLEABLE-IRON THREADED FITTINGS: ASME B16.3, CLASSES 150 AND 300.
D. MALLEABLE-IRON UNIONS: ASME B16.39, CLASSES 150, 250, AND 300.
E. CAST-IRON PIPE FLANGES AND FLANGED FITTINGS: ASME B16.1, CLASSES 25, 125, AND 250; RAISED GROUND FACE, AND BOLT HOLES SPOT FACED.
F. WROUGHT-STEEL FITTINGS: ASTM A 234/A 234M, WALL THICKNESS TO MATCH ADJOINING PIPE.
G. WROUGHT CAST- AND FORGED-STEEL FLANGES AND FLANGED FITTINGS: ASTM B16.5, INCLUDING BOLTS, NUTS, AND GASKETS OF THE FOLLOWING MATERIAL GROUP, END CONNECTIONS, AND FACINGS.
1. MATERIAL GROUP: 1.1. END CONNECTIONS: 40100.
2. FACINGS: RAISED FACE.
H. GROOVED MECHANICAL-JOINT FITTINGS AND COUPLINGS: MANUFACTURERS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCTS BY ONE OF THE FOLLOWING:
1. ANVI INTERNATIONAL, INC.
2. CENTRAL SPRINKLER COMPANY; A DIVISION OF TYCO FIRE & BUILDING PRODUCTS.
3. NATIONAL FITTINGS, INC.
4. S.P. FITTINGS; A DIVISION OF STAR PIPE PRODUCTS.
5. VICTAULIC COMPANY.
I. JOINT FITTINGS: ASTM A 536, GRADE 65-45-12 DUCTILE IRON; ASTM A 47/A 47M, GRADE 32510 MALLEABLE IRON; ASTM A 53/A 53M, TYPE F, OR S, GRADE B FABRICATED STEEL; OR ASTM A 106, GRADE B STEEL FITTINGS WITH GROOVES OR SHOULDERS.
J. CHILLED-WATER PIPING, ABOVEGROUND, NPS 2 (DN 50) AND LARGER, SHALL BE ANY OF THE FOLLOWING:
1. SCHEDULE 40 STEEL PIPE, WROUGHT-STEEL FITTINGS AND WROUGHT-CAST OR FORGED-STEEL FLANGES AND FLANGE FITTINGS, AND WELDED AND FLANGED JOINTS.
2. SCHEDULE 40 STEEL PIPE, GROOVED, MECHANICAL JOINT COUPLING AND FITTINGS; AND GROOVED, MECHANICAL JOINTS.
K. CONDENSATE-DRAIN PIPING: TYPE M (C) DRAWN-TEMPER COPPER TUBING, WROUGHT-COPPER FITTINGS, AND SOLDERED JOINTS.
L. HANGERS AND SUPPORTS: INSTALL THE FOLLOWING PIPE ATTACHMENTS:
1. ADJUSTABLE STEEL CLEVIS HANGERS FOR INDIVIDUAL HORIZONTAL PIPING LESS THAN 20 FEET (6 M) LONG.
2. ADJUSTABLE ROLLER HANGERS AND SPRING HANGERS FOR INDIVIDUAL HORIZONTAL PIPING 20 FEET (6 M) OR LONGER.
3. PIPE ROLLER: MSS SP-58, TYPE 44 FOR MULTIPLE HORIZONTAL PIPING 20 FEET (6 M) OR LONGER, SUPPORTED ON A TRAPEZE.
4. SPRING HANGERS TO SUPPORT VERTICAL RISERS.
5. PROVIDE COPPER-CLAD HANGERS AND SUPPORTS FOR HANGERS AND SUPPORTS IN DIRECT CONTACT WITH COPPER PIPE.
M. INSTALL HANGERS FOR STEEL PIPING WITH THE FOLLOWING MAXIMUM SPACING AND MINIMUM ROD SIZES:
1. NPS 3/4 (DN 20): MAXIMUM SPAN, 7 FEET (2.1 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
2. NPS 1 (DN 25): MAXIMUM SPAN, 7 FEET (2.1 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
3. NPS 1-1/2 (DN 40): MAXIMUM SPAN, 9 FEET (2.7 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
4. NPS 2 (DN 50): MAXIMUM SPAN, 10 FEET (3 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
5. NPS 2-1/2 (DN 65): MAXIMUM SPAN, 11 FEET (3.4 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
6. NPS 3 (DN 80): MAXIMUM SPAN, 12 FEET (3.7 M); MINIMUM ROD SIZE, 1/2 INCH (12.7 MM).
7. NPS 4 (DN 100): MAXIMUM SPAN, 14 FEET (4.3 M); MINIMUM ROD SIZE, 1/2 INCH (12.7 MM).
8. NPS 4 (DN 150): MAXIMUM SPAN, 15 FEET (4.6 M); MINIMUM ROD SIZE, 1/2 INCH (12.7 MM).
9. NPS 6 (DN 200): MAXIMUM SPAN, 19 FEET (5.8 M); MINIMUM ROD SIZE, 5/8 INCH (16 MM).
10. NPS 8 (DN 250): MAXIMUM SPAN, 20 FEET (6.1 M); MINIMUM ROD SIZE, 3/4 INCH (19 MM).
11. NPS 12 (DN 300): MAXIMUM SPAN, 23 FEET (7 M); MINIMUM ROD SIZE, 7/8 INCH (22 MM).
12. NPS 14 (DN 350): MAXIMUM SPAN, 25 FEET (7.6 M); MINIMUM ROD SIZE, 1 INCH (25 MM).
N. INSTALL HANGERS FOR DRAWN-TEMPER COPPER PIPING WITH THE FOLLOWING MAXIMUM SPACING AND MINIMUM ROD SIZES:
1. NPS 3/4 (DN 20): MAXIMUM SPAN, 5 FEET (1.5 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
2. NPS 1 (DN 25): MAXIMUM SPAN, 5 FEET (1.5 M); MINIMUM ROD SIZE, 1/4 INCH (6.4 MM).
3. NPS 1-1/2 (DN 40): MAXIMUM SPAN, 6 FEET (1.8 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
4. NPS 2 (DN 50): MAXIMUM SPAN, 8 FEET (2.4 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
5. NPS 2-1/2 (DN 65): MAXIMUM SPAN, 9 FEET (2.7 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
6. NPS 3 (DN 80): MAXIMUM SPAN, 10 FEET (3 M); MINIMUM ROD SIZE, 3/8 INCH (10 MM).
O. CHILLED WATER AND BRINE, ABOVE 40 DEG F (5 DEG C):
1. NPS 12 (DN 300) AND SMALLER: INSULATION SHALL BE THE FOLLOWING: MINERAL-FIBER, PREFORMED PIPE, TYPE L, 1-1/2 INCHES (38 MM) THICK.
2. NPS 14 (DN 350) AND LARGER: INSULATION SHALL BE ONE OF THE FOLLOWING: MINERAL-FIBER PREFORMED PIPE, TYPE L, 1-1/2 INCHES (38 MM) THICK.
P. CONDENSATE AND EQUIPMENT DRAIN WATER BELOW 60 DEG F (16 DEG C):
1. ALL PIPE SIZES: INSULATION SHALL BE ONE OF THE FOLLOWING: MINERAL-FIBER, PREFORMED PIPE INSULATION, TYPE L: 1 INCH (25 MM) THICK.

DUCT INSULATION

- A. MINERAL-FIBER BLANKET INSULATION: MINERAL OR GLASS FIBERS BONDED WITH A THERMOSETTING RESIN...
B. MINERAL-FIBER ADHESIVE: COMPLY WITH MIL-A-3316C, CLASS 2, GRADE A...
C. ASJ ADHESIVE AND FSK JACKET ADHESIVE: COMPLY WITH MIL-A-3316C, CLASS 2, GRADE A...
D. MASTICS: MATERIALS SHALL BE COMPATIBLE WITH INSULATION MATERIALS, JACKETS, AND SUBSTRATES...
E. VAPOR-BARRIER MASTIC: WATER BASED; SUITABLE FOR INDOOR USE ON BELOW AMBIENT SURFACES...
F. SEALANTS: FSK AND METAL JACKET FLASHING SEALANTS; PRODUCTS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS...
G. FSK TAPE: FOL-FACE, VAPOR-RETARDER TAPE MATCHING FACTORY-APPLIED JACKET WITH ADHESIVE...
H. INSULATION PINS AND HANGERS: CAPACITOR-DISCHARGE WELD PINS, FULLY ANNEALED FOR CAPACITOR-DISCHARGE WELDING...
I. INSULATION PINS AND HANGERS: CAPACITOR-DISCHARGE WELD PINS, FULLY ANNEALED FOR CAPACITOR-DISCHARGE WELDING...
J. INSTALLATION OF MINERAL-FIBER INSULATION: BLANKET INSULATION INSTALLATION ON DUCTS AND PLENUMS; SECURE WITH ADHESIVE AND INSULATION PINS...
K. OVERLAP UNFACED BLANKETS A MINIMUM OF 2 INCHES (50 MM) ON LONGITUDINAL SEAMS AND END JOINTS...
L. INSULATION PINS AND HANGERS: CAPACITOR-DISCHARGE WELD PINS, FULLY ANNEALED FOR CAPACITOR-DISCHARGE WELDING...
M. CONDENSATE AND EQUIPMENT DRAIN WATER BELOW 60 DEG F (16 DEG C):
1. ALL PIPE SIZES: INSULATION SHALL BE ONE OF THE FOLLOWING: MINERAL-FIBER, PREFORMED PIPE INSULATION, TYPE L: 1 INCH (25 MM) THICK.

DUCT LINER

- A. FIBROUS-GLASS DUCT LINER: COMPLY WITH ASTM C 1071, NFPA 90A, OR NFPA 90B; AND WITH NFPA A1124, "FIBROUS GLASS DUCT LINER STANDARD."
B. MAXIMUM THERMAL CONDUCTIVITY: TYPE L, FLEXIBLE: 0.27 BTU X IN./H X SQ. FT. X DEG F (0.039 W/M X K) AT 75 DEG F (24 DEG C) MEAN TEMPERATURE; R6 EQUIVALENT. TYPE R, RIGID: 0.23 BTU X IN./H X SQ. FT. X DEG F (0.033 W/M X K) - R6 EQUIVALENT. ANTIMICROBIAL EROSION-RESISTANT COATING: APPLY TO SURFACE OF THE LINER THAT WILL FORM THE INTERIOR SURFACE OF THE DUCT TO ACT AS A MOISTURE REPLENT AND EROSION-RESISTANT COATING. ANTIMICROBIAL AGENTS ARE REGISTERED TRADEMARKS BY AN RLT AND REGISTERED BY THE EPA FOR USE IN HVAC SYSTEMS. WATER-BASED LINER ADHESIVE: COMPLY WITH NFPA 90A OR NFPA 90B AND WITH ASTM C 916. FOR INDOOR APPLICATIONS USE ADHESIVE WITH A VOC CONTENT OF 80 G/L OR LESS WHEN CALCULATED ACCORDING TO 40 CFR 59, SUBPART D (EPA METHOD 24).
C. SHOP APPLICATION OF DUCT LINER: COMPLY WITH SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE," FIGURE 7-11, "FLEXIBLE DUCT LINER INSTALLATION." ADHERE A SINGLE LAYER OF INDICATED THICKNESS OF DUCT LINER WITH 100 PERCENT ADHESIVE COVERAGE AT LINER SURFACE AREA. ATTAINING INDICATED THICKNESS WITH MULTIPLE LAYERS OF DUCT LINER IS PROHIBITED.

DUCT LINER

- A. FIBROUS-GLASS DUCT LINER: COMPLY WITH ASTM C 1071, NFPA 90A, OR NFPA 90B; AND WITH NFPA A1124, "FIBROUS GLASS DUCT LINER STANDARD."
B. MAXIMUM THERMAL CONDUCTIVITY: TYPE L, FLEXIBLE: 0.27 BTU X IN./H X SQ. FT. X DEG F (0.039 W/M X K) AT 75 DEG F (24 DEG C) MEAN TEMPERATURE; R6 EQUIVALENT. TYPE R, RIGID: 0.23 BTU X IN./H X SQ. FT. X DEG F (0.033 W/M X K) - R6 EQUIVALENT. ANTIMICROBIAL EROSION-RESISTANT COATING: APPLY TO SURFACE OF THE LINER THAT WILL FORM THE INTERIOR SURFACE OF THE DUCT TO ACT AS A MOISTURE REPLENT AND EROSION-RESISTANT COATING. ANTIMICROBIAL AGENTS ARE REGISTERED TRADEMARKS BY AN RLT AND REGISTERED BY THE EPA FOR USE IN HVAC SYSTEMS. WATER-BASED LINER ADHESIVE: COMPLY WITH NFPA 90A OR NFPA 90B AND WITH ASTM C 916. FOR INDOOR APPLICATIONS USE ADHESIVE WITH A VOC CONTENT OF 80 G/L OR LESS WHEN CALCULATED ACCORDING TO 40 CFR 59, SUBPART D (EPA METHOD 24).
C. SHOP APPLICATION OF DUCT LINER: COMPLY WITH SMOACNA'S "HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE," FIGURE 7-11, "FLEXIBLE DUCT LINER INSTALLATION." ADHERE A SINGLE LAYER OF INDICATED THICKNESS OF DUCT LINER WITH 100 PERCENT ADHESIVE COVERAGE AT LINER SURFACE AREA. ATTAINING INDICATED THICKNESS WITH MULTIPLE LAYERS OF DUCT LINER IS PROHIBITED.