

264 FM 969 BLDG 3
BASTROP, TEXAS 78602

BASTROP FIRE DEPARTMENT	
FIRE DESIGN CODES	IFC 2018 W/ COA LOCAL AMENDMENTS
FIRE FLOW DEMAND @ 20 PSI	1,500 GPM
INTENDED USE	COMMERCIAL
CONSTRUCTION CLASSIFICATION	V-A
BUILDING FIRE AREA (SF)	2,947 sf
AUTOMATIC FIRE SPRINKLERS	NO
REDUCED FIRE FLOW DEMAND	NO
AFD FIRE HYDRANT FLOW TEST DATE	
AFD FIRE HYDRANT FLOW TEST LOCATION	

NOTE: ALL RESPONSIBILITY FOR THE ADEQUACY OF THESE PLANS REMAINS WITH THE ENGINEER WHO PREPARED THEM. IN REVIEWING THESE PLANS, THE CITY OF BASTROP MUST RELY UPON THE ADEQUACY OF THE DESIGN ENGINEER.

NO.	REVISION / CORRECTIONS DESCRIPTION	REVISE (R) ADD (A) VOID (V) SHEET NO'S	TOTAL # SHEETS IN PLAN SET	NET CHANGE IMP. COVER (SQ. FT)	TOTAL SITE IMP. COVER (SQ. FT.)/(%)	BASTROP APPROVAL/DATE	BASTROP APPROVED BY	DATE IMAGED	TRANS COUNT APPROVED DATE	TNR APPROVED BY
-----	------------------------------------	--	----------------------------	--------------------------------	-------------------------------------	-----------------------	---------------------	-------------	---------------------------	-----------------

C-1