

1" AIR SPACE MIN.
1 1/2" AIR SPACE PREFERRED

DW-10HS VENEER ANCHOR AT 16" O.C. VERT.
16" O.C. HORIZ. MAX

SCHED. BRICK W/ 3/8" THICK
MORTAR JOINT

1/2" SHEATHING WITH 1 LAYER OF
WATERPROOFING MEMBRANE

WATERPROOFING TAPE

SOLDIER COURSE
MATCH FIELD BRICK
RE: SCHED. SHEET A-6.00

SELF-ADHESIVE BUTYL FLASHING WITH
PRIMER. SEAL LEADING EDGE
WITH MASTIC

PAINTED LOOSE GALVANIZED
LINTEL RE: STRUCTURAL
DRAWINGS

R-20 UNFACED INSULATION

2x6 WOOD STUD @ 16" O.C.

GALVANIZED SELF-DRILLING SCREW
TO BE FLUSH WITH THE FACE OF ZIP
SYSTEM PANEL OVER DRIVEN
SCREWS SHALL BE TAPED

HEADER
RE: STRUCTURAL

5/8" THICK SHEET ROCK. TAPE AND FLOAT.

POCKET FILLER

SCHED. WINDOW RE: A-2.00

1 1/2" GALVANIZED SELF DRILLING SCREW

SEALANT OVER BACKER ROD

SELF-ADHEARING FLASHING UNDER SILL PAN; LAP OVER ZIP SYSTEM PANEL 4" MIN.

CAST STONE SILL (SLOPE 1:12 MIN.)

DRIP EDGE KERF CUT

AIR WEEP VENTS

1/2" ZIP SHEATHING WITH 40ML FLUID APPLIED WATERPROOFING MEMBRANE

DW-10HS VENEER ANCHOR AT 16" O.C. VERT. 16" O.C. HORIZ. MAX

SCHED. STONE W/ 3/8" THICK MORTAR JOINT

SCHED. WINDOW RE: A-2.00

CAULKING

SILL PAN SCREW BEHIND GYP.BD.

SILL PLAN BEADED IN FULL BED OF SEALANT FASTENED TO SILL PLATE

2x6 WOOD SILL PLATE

2x6 WOOD STUD @ 16" O.C.

GALVANIZED SELF-DRILLING SCREW TO BE FLUSH WITH THE FACE OF ZIP SYSTEM PANEL. OVER DRIVEN SCREWS SHALL BE TAPED

R-20 UNFACED INSULATION

5/8" THICK SHEET ROCK. TAPE AND FLOAT.

3' - 2"

3' - 2 5/8"

MT-01 PREFINISHED STANDING SEAM METAL ROOF OVER 40MIL ICE AND WATER SHIELD ON 5/8" APA RATED DECK

STAINED CEDAR 4X4 DIAGONAL BRACE

STAINED CEDAR 4X4 HORIZONTAL INTO VERTICAL LEG AND NOTCHED FOR DIAGONAL BRACES

STAINED CEDAR 4X4 DIAGONAL BRACE

STAINED CEDAR 2X4 VERTICAL NOTCHED FOR DIAGONAL BRACE

MT-01 PREFINISHED SEAM METAL ROOF OVER 40MIL ICE AND WATER SHIELD ON 5/8" APA RATED DECK

6' - 0"

BOLT

STAINED CEDAR 4X4 HORIZONTAL INTO 4X4 HORIZONTAL

5' - 3"

0' - 1"

0' - 3 1/2"

0' - 3 1/2"

0' - 1"

DW-10HS VENEER ANCHOR AT 16" O.C. VERT. 16" O.C. HORIZ. MAX

SCHED. STONE W/ 3/8" THICK MORTAR JOINT

1/2" ZIP SHEATHING WITH FLUID APPLIED WATERPROOFING MEMBRANE

MORTAR TRAP

WEEP HOLE @ 5'-0" O.C. TYP.

SELF-ADHESIVE BUTYL FLASHING WITH PRIMER. SEAL LEADING EDGE WITH MASTIC. FASTEN TO VERTICAL FACE OF BRICK LEDEG ONLY

5/8" THICK SHEET ROCK, TAPE AND FLOAT.

GALVANIZED SELF-DRILLING SCREW TO BE FLUSH WITH THE FACE OF ZIP SYSTEM PANEL. OVER DRIVEN SCREWS SHALL BE TAPED

R-20 UNFACED INSULATION

2"x6" BASE PLATE

FOUNDATION ANCHOR RE: STRUCTURAL

FOUNDATION RE: STRUCTURAL

Diagram illustrating the connection of a glass curtain wall system to a concrete slab. The system includes a continuous 2x4 wood sill and a continuous 2x6 wood sill. The glass is supported by a 2" RACO BR glass frame. The connection is secured with 2x6 wood studs at 16" O.C. The height of the glass panel is indicated as 3' - 2 3/4". The distance from the top of the glass to the top of the concrete slab is labeled as 0' - 1 1/2". The distance from the top of the glass to the top of the concrete slab is labeled as VARIES.

 BUILDING AWNING
1" = 1'-0"

[illegible]

DRAWING TITLE		A-9.10
TYP. DETAILS		
DRAWN BY	RG	
CHECKED BY	BL	
APPROVED BY		TB