

SYSTEM	DESIGNATION OR ITEM NUMBER	EQUIPMENT DESCRIPTION	ITEM CFH	TOTAL CFH
EQUIPMENT				
	1	NATURAL GAS GENERATOR	1889	
SUBTOTAL				1889
SAFETY	20% SAFETY FACTOR		379	
TOTAL GAS LOAD				2267
SYSTEM INFORMATION				
SIZED FROM TABLE IPC 2018				
		INLET PRESSURE (PSI)	2	
		TOTAL DEVELOPED LENGTH IN FEET	5'	
		PRESSURE DROP (PSI)	1	
		SPECIFIC GRAVITY	0.60	

1. GAS PIPING INSTALLATION SHALL FOLLOW THE 2018 INTERNATIONAL PLUMBING CODE WITH ALL LOCAL AMENDMENTS. ALL GAS PIPING 2" LARGER LOCAL ABOVE GRADE SHALL BE SCHEDULE 40 BLACK STEEL (ASTM A54) WELDED JOINTS. ALL GAS PIPING ABOVE GRADE 1 1/2" AND SMALLER SHALL BE SCHEDULE 40 BLACK STEEL PIPE (ASTM A53) WITH THREADED JOINTS AND 150 # 1/2" THREADED MALLEABLE IRON FITTING (ASTM A47). ALL GAS PIPING BELOW GRADE 1 1/2" AND SMALLER SHALL BE POLYETHYLENE (PE) TUBING (ASTM D2513) WITH JOINTS PER MANUFACTURERS RECOMMENDATION.
2. THREADED JOINTS SHALL BE MADE WITH A MIXTURES OF GRAPHITE AND OIL APPLIED TO MALE THREADS ONLY. PIPE SHALL BE REAMED AND SHALL HAVE BURRS REMOVED PRIOR TO THREADING.
3. WELDED JOINTS SHALL BE FUSION WELDED IN ACCORDANCE WITH THE AMERICAN STANDARDS CODE FOR PRESSURE PIPE, ANSI B31.1, SECTION 6.
4. UNIONS SHALL BE 150# SOCKET WELDED CARBON STEEL CONFORMING TO FEDERAL SPECIFICATION WW-U-53C.
5. VALVES 3" AND LARGER SHALL BE SEMI-STEEL PLUG VALVES WITH CAST IRON BODY, LUBRICATED CAST IRON PLUG, FLANGED ENDS AND WRENCH OPERATED FOR 175# WOG.
6. VALVES 2 -1/2" AND SMALLER SHALL HAVE BRONZE BODY AND PLUG, SOCKET WELDED ENDS AND SQUARE HEAD FOR 125 WOG.
7. LUBRICATED PLUG VALVES SHALL BE LUBRICATED AT THE FACTORY AND SEALANT SHALL BE SUITED FOR NATURAL GAS.
8. PROVIDE SCHEDULE 40 PIPE SLEEVE WHERE PIPE PASSES THROUGH WALLS.
9. PIPING ON THE ROOF SHALL BE SUPPORTED EVERY 10'-0" (AND 2'-0" FROM A CHANGE IN DIRECTION) WITH FABRICATED STEEL PIPE STANDS AND INTEGRAL PIPE CLAMPS FOR SECURING HORIZONTAL PIPING. PIPE STANDS SHALL BE SECURED TO THE ROOF PER THE ROOFING MANUFACTURERS INSTALLATION REQUIREMENTS.
10. PROVIDE 6" LONG DRIP LEGS AT ENDS OF HORIZONTAL RUNS, AT THE BASE OF RISERS AND AT CONNECTIONS TO EQUIPMENT.
11. PLUMBING CONTRACTOR SHALL CONNECTIONS GAS PIPE ROUTING, GAS METER LOCATIONS, GAS METER AND REGULATOR SIZES AND PRESSURE SETTINGS WITH THE OWNER AND GAS COMPANY BASED ON INDIVIDUAL TENANT FIT-OUT DEMANDS. FOR EXISTING METERS CONTRACTOR SHALL VERIFY WITH THE LOCAL GAS COMPANY THAT EXISTING METER CAN HANDLE THE GAS DEMAND. FOR THE PROJECT AND SHALL COORDINATE NEW METER INSTALLATION AND PAY ALL FEES ASSOCIATED.

1. ALL CONTRACT DOCUMENTS (SPECIFICATIONS AND DRAWINGS), I.E., ARCHITECTURAL, STRUCTURAL, MECHANICAL, PLUMBING, FIRE PROTECTION AND ELECTRICAL ARE COMPLEMENTARY AND MUST BE USED IN COMBINATION TO OBTAIN COMPLETE CONSTRUCTION INFORMATION.
2. ALL CONFLICTS, WHICH MAY PREVENT THE COMPLETION OF WORK AS INTENDED, SHALL BE BROUGHT TO THE ARCHITECT'S ATTENTION. THE CONTRACTOR SHALL NOT PROCEED WITH ANY RELATED WORK UNTIL ALL CONFLICTS ARE RESOLVED AND THE CLARIFYING INFORMATION IS ISSUED TO THE CONTRACTOR BY THE ARCHITECT.
3. IT IS THE INTENTION OF THESE DRAWINGS TO CALL FOR FINISHED WORK, I.E., FULLY ADJUSTED, TESTED, AND READY FOR OPERATION. WHEREVER THE WORD "PROVIDE" IS USED, IT SHALL MEAN, "FURNISH AND INSTALL COMPLETE AND READY FOR USE."
4. THE PLUMBING DRAWINGS ARE DIAGRAMMATIC AND DO NOT NECESSARILY SHOW EVERY COMPONENT AND/OR ACCESSORY REQUIRED FOR A COMPLETE INSTALLATION. THE CONTRACTOR SHALL INCLUDE SUCH ITEMS AS ARE REQUIRED TO ENSURE THAT THE ENTIRE SYSTEM IS FUNCTIONING IN COMPLIANCE WITH APPLICABLE CODE, ACCEPTED INDUSTRY STANDARDS, AND MANUFACTURER'S INSTALLATION REQUIREMENTS/RECOMMENDATIONS UPON COMPLETION OF THE WORK.
5. ALL CUTTING, DRILLING AND PATCHING OF WALLS, FLOORS, AND/OR STRUCTURAL MEMBERS FOR THE INSTALLATION OF THE PLUMBING AND FIRE PROTECTION SYSTEMS SHALL BE PROVIDED. STRUCTURAL COMPONENTS SHALL NOT BE CUT, DRILLED OR MODIFIED IN A WAY WITHOUT THE STRUCTURAL ENGINEER'S REVIEW AND PRIOR WRITTEN APPROVAL.
6. PROVIDE NFPA APPROVED FIRE STOPPING WHERE PIPES PENETRATE FIRE RATED WALLS AND WALLS.

SYMBOL	DESCRIPTION	SIZE OF CONNECTION					REMARKS	WATER CONSERVATION
		TRAP	SS	SV	CW	HW		
BFP-1	BACKFLOW PREVENTER	-	-	-	3/8"	-	WATTS No. LF7. 1/4" BACKFLOW PREVENTER WITH BRONZE. LEAD FREE.	
TMV-1	THERMOSTATIC MIXING VALVE	-	-	-	1/2"	1/2"	LEONARD MODEL NO 170 BRONZE BODY WITH LOCK TEMPERATURE ADJUSTMENT CAP. SET TEMP. @ 110°.	
WF-1	WATER FILTER	-	-	-	3/4"	-	AQUA PURE MODEL NO AP717	
WC-1	WATER CLOSET	-	4"	2"	1"	-	AMERICAN STANDARD NO. 215AA104 "CADET" 1.28 GPF 15" VITREOUS CHINA, FLOOR MOUNTED GRAVITY FED WATER CLOSET WITH ELONGATED BOWL. CHURCH 9500C WHITE FRONT SEAT WITH CONCEALED STAINLESS STEEL SELF-SUSTAINING AND EXTERNAL CHECK HINGE.	
L-1	LAVATORY HANDICAPPED	1 1/4"	2"	2"	1/2"	1/2"	AMERICAN STANDARD NO. 9024.000EC "DECORUM" 20" x 18-1/4" VITREOUS CHINA, WALL HUNG MOUNTED LAVATORY, AMERICAN STANDARD NO. 7426801.243 "BELMEADE" AND MCGUIRE# 8872 CAST BRASS P-TRAP WITH CLEANOUT PLUG, MCGUIRE # 155A CAST BRASS P.O. PLUG WITH OPEN GRID STRAINER AND 17 GAUGE TAILPIPE, MCGUIRE # 216SLK SUPPLIES WITH RISER AND WALL ESCUTCHEON, ZURN FLR. MTD. CARRIER/ RECTANGULAR UPRIGHTS. ANGLE SUPPLY AND P-TRAP SHALL BE INSULATED WITH TRAP WRAP BY BROCAR PRODUCTS, INC. OR APPROVED EQUAL.	
MS-1	SERVICE SINK	3"	3"	2"	1/2"	1/2"	FIAT PRODUCTS No. MSB2424 OR APPROVED EQUAL WHITE (24"x24") SERVICE SINK WITH 10" HIGH WALLS, 3" STAINLESS STEEL COMBINATION DOME STRAINER AND LINT BASKET OUTLET, ACID RESISTANT, MOLDED STONE (COLOR AS SPECIFIED BY ARCHITECT). REMOVABLE VINYL-COATED RM GUARD No. V-70-24. SINK FITTING CHICAGO 897-RCF OR 1&S No. B-0665-BSTR ROUGH CHROME PLATED BRASS FINISH, RIGID SPOUT, WALL BRACE, INTEGRAL STOPS, PAIL HOOK, HOSE END, VACUUM BREAKER AND GANDAL PROOF SCREWS. PROVIDE 30" HOSE (MINIMUM) WITH STAINLESS STEEL BRACKET (EQUAL TO STERN - WILLIAMS No. T-35) AND STAINLESS STEEL MOP HANGER (EQUAL TO STERN - WILLIAMS No. T-40). PROVIDE 12" HIGH, 20 GAUGE TYPE 316 STAINLESS STEEL SPLASH GUARDS ON ALL WALLS ADJACENT TO THE SERVICE SINK. PROVIDE AND INSTALL INTERNAL WALL SUPPORTS IN ACCORDANCE WITH THE ARCHITECTS REQUIREMENTS FOR THE WALL BRACE ATTACHMENTS.	
EDF-1	ELECTRIC DRINKING FOUNTAIN	1-1/4"	2"	2"	1/2"	----	HALSEY TAYLOR HTHB-HACDBLSS-NF ADA BARRIER-FREE TWO LEVEL WALL MOUNT FOUNTAIN. MCGUIRE NO. 8088 CHROME-PLATED ADJUSTABLE P-TRAP WITH CLEANOUT PLUG, 1-1/4" TRAP NIPPLE AND CHROME-PLATED STOP VALVE IN COLD WATER LINE LOCATED INSIDE CABINET. REFER TO ARCHITECT FOR MOUNTING HEIGHTS.	
FD-1	FLOOR DRAIN	3"	3"	2"	1/2"	-	J.R. SMITH FIGURE NO. 2005Y-A06NB-P OR APPROVED EQUAL PAINTED CAST IRON FLOOR DRAIN AND SEEPAGE FLANGE, SIZE AS NOTED ON DRAWINGS, CLAMPING UNIT, QUAD CLOSE TRAP SEAL, AND 6" ROUNDE ADJUSTABLE POLISHED NICKEL BRONZE STRAINER TYPE TOP AND DEEP SEAL TRAP.	
WH-1	WALL HYDRANT	-	-	-	3/4"	-	MIFAB MHY-26-6, NON-FREEZE, ENCLOSED FLUSH, ANTI-CONTAMINATION WALL HYDRANT WITH VACUUM BREAKER, HARDENED STAINLESS STEEL INTERIOR PARTS, 3/4" HOSE CONNECTION, STAINLESS STEEL BOX FACE AND HINGED COVER WITH OPERATING KEY LOCK, OPERATING KEY AND NON-FREEZE VALVE.	
RVB-1	REFRIGERATOR VALVE BOX	-	-	-	1/2"	-	GUY GRAY #BIM-875 10-3/4" x 9" 16GA. STEEL WITH EPOXY FINISH , 3/8" O.D. SWEAT CONNECTION PROVIDE FILLER WHEN MAKING FINAL CONNECTION, AQUA-PURE #AP717	
SK-1	SINK HANDICAPPED	1-1/2"	2"	2"	1/2"	1/2"	ELKAY No. ELUHAD281655 SINGLE COMPARTMENT STAINLESS STEEL UNDERMOUNTED SINK, 18 GAUGE SELF-RIMMING (31" x 16" x 4" DEEP), KOHLER No. K-647 FAUCET, PROVIDE TMV-1, ANGLE SUPPLIES WITH STOP, 1/2" CHROME-PLATED BRASS NIPPLES TO WALL, MCGUIRE No. 151-A CRUMB CUP STRAINER, No. 8912 (1-1/2") ADJUSTABLE SEMI-CAST CHROME-PLATED BRASS P-TRAP WITH TUBING WASTE TO WALL AND CHROME-PLATED CAST WALL FLANGE WITH SET SCREW SUPPLIES, AND P-TRAP SHALL BE INSULATED WITH TRAP WRAP BY PLUMBEREX SPECIALTY PRODUCTS, INC OR APPROVED EQUAL.	

MARK	SERVICE	STORAGE IN GALLONS	RECOVERY AT 100° RISE	ELECTRICAL	ELEMENT WATTS	MAKE AND MODEL
<u>FWH-1</u>	ELECTRIC WATER HEATER	20	12 GPH	208/1ø/60Hz	3KW	A.O. SMITH MODEL NO. DEL-20

SYMBOL	DESCRIPTION
	SANITARY SEWER PIPING
	VENT PIPING
	DOMESTIC COLD WATER
	DOMESTIC HOT WATER
	DOMESTIC HOT WATER RETURN
	EXISTING SANITARY SEWER PIPING
	EXISTING VENT PIPING
	EXISTING DOMESTIC COLD WATER
	EXISTING HOT WATER
	EXISTING HOT WATER RETURN
	NEW CONNECTION TO EXISTING
AFF	ABOVE FINISHED FLOOR
BF	BELOW FLOOR
	GATE VALVE
	CHECK VALVE
	PRESSURE RELIEF VALVE
	UNION
	PRESSURE GAUGE
	THERMOMETER
	CONDENSATE DRAIN LINE
(E)	EXISTING
(D)	ITEMS TO BE REMOVED
	ELBOW UP
	ELBOW RISE OR DN. THROUGH SLAB
	CLEANOUT
	CLEANOUT
	FLOOR DRAIN

DISREGARD LEGEND ITEMS NOT INDICATED ON DRAWINGS

PIPING FUNCTION	PIPING MATERIAL
SANITARY WASTE BELOW GRADE	SCHEDULE 40 PVC
SANITARY WASTE ABOVE GROUND	NO-HUB CAST IRON
SANITARY VENT	NO-HUB CAST IRON
DOMESTIC HOT & COLD WATER	COPPER, TYPE "L" HARD DRAWN
FIRE SPRINKLER ABOVE GROUND	BLACK STEEL SCHEDULE 40

NOTE:
NO HUB COUPLING SHALL HAVE A SHIELD CONSTRUCTED OF 304 CORRUGATED, STAINLESS STEEL WITH A MINIMUM THICKNESS OF .016. COUPLING SIZE 1-1/2" - 4" SHALL HAVE FOUR (4) BANDS: APPROVED MANUFACTURES HUSKY SD 4000 AND MISSION. NO TWO BANDS ARE ACCEPT

INDICATED ON DRAWINGS

FIXTURES							
SYMBOLS	DESCRIPTION	SIZE OF CONNECTION					
		SANITARY	TRAP	VENT	C.W.	H.W.	I.W.
 W C	WATER CLOSET (FLUSH VALVE)	4"	—	2"	1"	—	—
 U	URINAL	2"	—	2"	3/4"	—	—
 L	LAVATORY	2"	1-1/4"	1-1/4"	1/2"	1/2"	—
 BT	BATH TUB	2"	1-1/2"	1-1/2"	1/2"	1/2"	—
 MS	MOP SINK	—	2"	2"	1/2"	1/2"	—
 SK—"X"	SINK (BY ARCHITECT)	—	1-1/2"	2"	1/2"	1/2"	—
 SH	SHOWER	—	2"	2"	1/2"	1/2"	—
 EDF	ELECTRIC DRINKING FOUNTAIN	—	1-1/4"	1-1/4"	1/2"	—	—
 DF	DRINKING FOUNTAIN	—	1-1/4"	1-1/4"	1/2"	—	1/2"

SYMBOL	DESCRIPTION	P.D.I. FIXTURE UNIT RATING	TYPE NO. PPP
<u>SA-A</u>	SHOCK ARRESTOR	1-11	SC-500
<u>SA-B</u>	SHOCK ARRESTOR	12-32	SC-750
<u>SA-C</u>	SHOCK ARRESTOR	33-60	SC-1000
<u>SA-D</u>	SHOCK ARRESTOR	61-113	SC-1250



15810 PARK TEN PLACE, SUITE 300
HOUSTON, TEXAS 77084
713-465-4650
www.sligroup.com

© COPYRIGHT

NBT
National Bank & Trust
National Bank & Trust - Bastrop

E/BE Project Number : 26129.00

ISSUED FOR CLIENT APPROVAL	DATE
ISSUED FOR BIDDING	09/11/26
ISSUED FOR PERMIT	09/11/26
ISSUED FOR CONSTRUCTION	

REVISIONS

[illegible][illegible]

DRAWING TITLE

PLUMBING INFORMATION

SHEET NO.

P-0.10